Circular Order No-1//2015 of Directorate General of FS, HGs & CD, Daisna, Catta

FORM III

FIRE SAFETY CERTIFICATE

File No-01/2015

Dated:26.06.2015 Certificate No- 916

This initial Certificate is valid up to 31st March 2016

(Apply for Renewal at least three months before expiry)

Certified that Ekalavya Model Residential School situated at Champanagar, Gandhipally under G.P.-Chalanguda, Block/PS/Dist- Malkangiri, PIN- 764049 consisting 8.406 Hc. area of total 09 number of blocks, was inspected by officers of the Fire Service on dated 24th June 2015 in presence of Sri Bibhuti Prasad Panda (TGT SSC) and Sri Prabhat Kumar Mohanty (Accountant) of the school. It has been found that:

- The construction work has been undertaken by the Nipani Industries, Jabalpur, MadhyaPradesh.
- 2. The nature of construction is:
 - (i) Foundation in RCC
 - (ii) Super Structure with Light Gauge Steel Frame
 - (iii) External Wall Cladding with BPGI Sheet
 - (iv) Internal Wall Cladding with Fibre Cement Board
 - (v) Roof is made with PTGI Sheet
 - (vi) Insulation Material is of Glass Wool.

However all these materials are used in construction are non-combustible in nature as per the certificate given by the above construction company.

- 3. There are 04(Four) Nos of ABC stored pressure type, 02 kg capacity each portable fire extinguishers are available in the school premises and also position in suitable places to meet any fire accident.
- 4. Apart from above, there are many water points to fetch water in case of any eventuality.

Further the management of the school is being advised to install 04(Four) Nos CO2 type 4.5kg capacity fire extinguishers as additional requirement for fire safety of the school to comply with the fire prevention and safety requirement in accordance with the Odisha Fire Prevention and safety rules, 2015

CONDITIONS:

- 1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained in best repairs and efficient working condition at all times for use by the occupants of the members of the Fire Service or both in the event of outbreak of fire.
- 2. The setbacks, driveways, entrance/exits, staircases, lobbies, corridors and escape ways should not be changed, obstructed or modified in any way nor any permanent or temporary structure or projections whatsoever be constructed/made therein.
- 3. All staff and occupants should be trained periodically to make them well conversant in use and operation of fire prevention and safety measures installed, and emergency drills/rehearsals organised at least once in six months by involving local Fire Station.
- 4. The occupier (s) shall appoint Fire Safety Supervisor exclusively for these premises as per rule 9 of the Odisha Fire Prevention and safety rules, 2015.
- 5. Photocopies of the Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all buildings/towers/blocks of this premises.

Asst Fire Officer

Matkangin F S

Simanchala Pathi, (Afo)